



125 volt 15- or 20-ampere receptacle on general purpose branch circuit, more than 6', and less than 20' from inside wall of pool. Must be GFCI protected. (680.22(A)(3))